

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0067:101 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: Siemens Building Technologies/Cerberus Division, 8 Fernwood Rd, Florham Park, NJ 07932 Contact: Peter Pawchak (973) 593-2662

DESIGN: Models DI3, DI-A3, DI-B3, DI-3H, DI-A3H, DI-B3H*, DI-X3, DI-X3H, DI-AX3H, DI-BX3, DI-BX3H, ID-60I, ID-60IA, ID-60IB, ID-60IH, ID-60IAH, and ID-60IBH ionization type smoke detectors with Model DB-3S or DB-X3RS base. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as ionization smoke detectors for use with separately listed compatible fire alarm control units. Models DI-B3, DI-B3H*, DI-BX3, DI-BX3H, ID-60IB and ID-60BH are intended for use with Model AD-3 duct detector housing/base (CSFM Listing No. 3240-0067:116).

NOTE: Formerly 7256-0067:101

*Rev 08-05-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager